

2015-5000

2016-02-08

BD 110

LIQUID MICROBIOCIDE

INDUSTRIAL

Controls the growth of algae, bacteria and fungi

READ THE LABEL BEFORE USING

REGISTRATION NO.: 22279

PEST CONTROL PRODUCTS ACT

WARNING

POISON – CORROSIVE

CORROSIVE TO EYES

SKIN IRRITANT

POTENTIAL SKIN SENSITIZER

GUARANTEE

Potassium dimethyldithiocarbamate...10% (by wt)

NET CONTENTS: liters/kilograms

ENVIRONMENTAL HAZARDS: This product is toxic to aquatic organisms. Keep out of lakes, streams or ponds. Do not contaminate water, food or feed by storage or disposal.

NOTICE TO USER:

This pest control product is to be used only in accordance with the directions on the label. It is an offence under the Pest Control Products Act to use this product in a way that is inconsistent with the directions on the label. The user assumes the risk to persons or property that arises from any such use of this product.

KIMIK'O Inc.

1375 - B Ernest - Harnois

Joliette, Québec J6E 0L7

1-450-867-1825

DIRECTIONS FOR USE

DO NOT discharge effluent containing this product into sewer systems, lakes, streams, ponds, estuaries, oceans or other waters.

DO NOT contaminate irrigation or drinking water supplies or aquatic habitats by cleaning of equipment or disposal of wastes.

1) Cooling Tower Systems:

Prior to use in water cooling towers, systems should be cleaned in order to remove organic, inorganic, microbiological deposits.. An initial slug addition of 800 ml to 1,200 ml per 10,000 liters of water should then be added to the sump of the cooling water towers. Repeat the initial dosage until control is evident. Subsequent slug additions of 400 ml to 1,200 ml per 10,000 liters of water should be added every 2 to 5 days or as needed. The frequency of addition will depend on the relative amount of bleed off and the severity of the microbiological problem.

1) Industrial Air Washing Systems:

Prior to use in air washers, systems should be cleaned to remove organic, inorganic and microbiological deposits. An initial slug addition of 186 ml to 236 ml per 1,000 liters of water should then be added to the sump or the water collector trays. Repeat the initial dosage until the

control is evident.

Subsequent slug additions of 86 ml to 236 ml per 1,000 liters of water should be added every 1 to 5 days or as needed. The frequency of addition will depend on the relative amount of bleedoff and the severity of the microbiological problem.

For use only in systems equipped with the effective mist eliminating components.

PRECAUTIONS

DANGER

KEEP OUT OF REACH OF CHILDREN

Corrosive to the eye. **DO NOT** get in eyes. Corrosive to skin. **DO NOT** get on skin. Potential skin sensitizer. Harmful if swallowed. Avoid contact with eyes, skin, clothing and the contamination of food. Wear long-sleeved shirt, long pants, chemical-resistant gloves, protective eyewear (goggles or face shield) when handling the product, clean-up and repair activities..

FIRST AID

Eye exposure: Hold eye open and rinse slowly and gently with water for 15-20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye. Call a poison control centre or doctor for treatment advice.

Contact with skin or clothing: Take off contaminated clothing. Rinse skin immediately with plenty of water for 15-20 minutes. Call a poison control centre or doctor for treatment advice.

Inhalation: Move person to fresh air. If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably by mouth-to-mouth, if possible. Call a poison control centre or doctor for further treatment advice.

Ingestion: Call a poison control centre or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told to do so by a poison control centre or doctor. Do not give anything by mouth to an unconscious person.

TOXICOLOGICAL INFORMATION: Note to physician. Probable mucosal damage following ingestion may contraindicate gastric lavage. Avoid giving alcohol or alcohol related products. Treat symptomatically.

DISPOSAL

1. Triple or pressure-rinse the empty container. Add the rinsings to the treatment site.
2. Follow the provincial instructions for any additional required cleaning of the container prior to its disposal.
3. Make the container unsuitable for further use.
4. Dispose of the container in accordance with the provincial requirements.
5. For information on the disposal of unused, unwanted product, contact the Provincial Regulatory Agency or the manufacturer. Contact the manufacturer and the Provincial Regulatory Agency in case of a spill and for clean up of spills