

2021-6463
2022-01-14

DANTOBROM[®] RW CANISTER TABLET

MICROBICIDE FOR CONTROL OF BACTERIA, FUNGI AND ALGAE IN
RECIRCULATING COOLING WATER SYSTEMS AND AIRWASHERS

COMMERCIAL

ACTIVE INGREDIENTS :

Available bromine present as 1-bromo-3-chloro-5,5-dimethylhydantoin and related
hydantoin.....39.2%

Available chlorine present as 1-bromo-3-chloro-5,5-dimethylhydantoin,
1,3-dichloro-5,5-dimethylhydantoin, 1,3-dichloro-5-ethyl-5-methylhydantoin and related
hydantoin.....44.4%

REGISTRATION NO. 23246 PEST CONTROL PRODUCTS ACT

READ THE LABEL BEFORE USING

WARNING



POISON



CORROSIVE

**DANGER – CORROSIVE TO EYES AND SKIN
POTENTIAL SKIN SENSITIZER**

NET CONTENTS: Kg

ARXADA, LLC
412 Mount Kemble Avenue, Suite 200S
Morristown NJ 07960

201-316-9200

2021-6463
2022-01-14

DIRECTIONS FOR USE:

DO NOT contaminate irrigation or drinking water supplies or aquatic habitats by cleaning of equipment or disposal of wastes.

DO NOT discharge effluent containing this product into sewer systems, lakes, streams, ponds, estuaries, oceans or other waters.

FOR USE IN CANISTERS

TO INSTALL CANISTER: Take feeder cap off. Remove canister cut offs. Hold canister so the open end faces down. Insert into feeder. The end of the canister must align with the L-key located inside the feeder at the bottom. **DO NOT FORCE.** Replace feeder cap. To achieve the proper halogen residual, turn the control dial to the appropriate setting and add the required product dosage. Refer to use directions for recirculating cooling water systems and airwasher systems, as appropriate. Check the canister periodically and replace when empty. Do not attempt to refill this canister. **DO NOT REUSE.** The warranty will be void if this canister is not used with the appropriate feeder. Fire or explosion may result if this canister is used with an incorrect chemical feeder. **NOTE:** Some settling may occur during shipment.

RECIRCULATING COOLING WATER SYSTEMS

DANTOBROM RW aids in the control of bacterial, fungal and algal slimes in evaporative condensers, heat exchange water towers, influent systems such as flow through filters, industrial water scrubbing systems and brewery pasteurizers. This product may be added to the systems either continuously or intermittently or as needed. The frequency of feeding and duration of the treatment will depend upon the severity of the problem. **BADLY FOULED SYSTEMS** must be cleaned before treatment is begun.

FOR CONTROL OF BACTERIA AND FUNGI

INTERMITTENT OR SLUG METHOD

INITIAL DOSE: When the system is noticeably fouled, add 60 to 600 g to 5000 Litres or 12 to 120 parts per million of the water in the system. Repeat until control is achieved. **SUBSEQUENT DOSE:** When microbial control is evident add 60 to 450 g to 5000 Litres or 12 to 90 parts per million of water in the system every 3 days or as needed to maintain control.

CONTINUOUS FEED METHOD

INITIAL DOSE: When a system is noticeably fouled, add 60 to 600 g to 5000 Litres or 12 to 120 parts per million of water in the system. **SUBSEQUENT DOSE:** Continuously feed to maintain a dosage of 60 to 450 g to 5000 Litres or 12 to 90 parts per million of water in the system.

FOR CONTROL OF ALGAE

INTERMITTENT OR SLUG METHOD

INITIAL DOSE: When the system is noticeably fouled add 60 to 600 g per 5000 Litres or 12 to 120 parts per million of water in the system. Repeat until control is achieved. **SUBSEQUENT DOSE:** When algae control is evident add 60 to 450 g to 5000 Litres daily or 12 to 90 parts per million daily or as needed to maintain control.

CONTINUOUS FEED METHOD

INITIAL DOSE: When the system is noticeably fouled add 60 to 600 g to 5000 Litres or 12 to 120 parts per million of water in the system. Repeat until control is achieved. **SUBSEQUENT DOSE:** Continuously feed to maintain a dosage of 60 to 450 g to 5000 Litres or 12 to 90 parts per million of water in the system.

AIRWASHERS

For use only in industrial airwasher systems that maintain effective mist eliminating components. DANTOBROM RW controls slime forming bacteria, fungi and algae in industrial airwasher systems. Add DANTOBROM RW at the rate of 60 to 600 g (12 to 120 ppm) per 5000 Litres of water in the system, depending upon the severity of the contamination. Control the application by measuring the free chlorine residual in the treated water. There is no need to exceed 1.0 ppm as free chlorine. Badly fouled systems must be cleaned before treatment is begun.

2021-6463
2022-01-14

INTERMITTENT OR SLUG METHOD

INITIAL DOSE: When system is noticeably fouled add to airwasher sump or chill water sump to insure uniform mixing. Add 60 to 600 g to 5000 Litres or 12 to 120 parts per million of water.

SUBSEQUENT DOSE: When microbial control is evident add 60 to 360 g to 5000 Litres or 12 to 72 parts per million of water.

CONTINUOUS FEED METHOD

INITIAL DOSE: When system is noticeably fouled add to air washer sump or chill water sump to insure uniform mixing. Add 60 to 600 g to 5000 Litres or 12 to 120 parts per million of water.

SUBSEQUENT DOSE: When microbial control is evident add 60 to 360 g to 5000 Litres or 12 to 72 parts per million.

PRECAUTIONS:

KEEP OUT OF REACH OF CHILDREN. HARMFUL IF SWALLOWED. HIGHLY CORROSIVE. DO NOT TAKE INTERNALLY. Irritating to nose and throat. Avoid breathing dust. Use with adequate ventilation. Corrosive to the eye and skin. Do not get into eyes, on skin or clothing. Potential skin sensitizer. Wear long pants, a long-sleeved shirt, chemical-resistant gloves and goggles or a face-shield while cleaning equipment and handling product. Wash thoroughly after handling. Immediately remove contaminated clothing and wash before reuse.

FIRST AID:

If in eyes: Hold eye open and rinse slowly and gently with water for 15-20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye. Call a poison control centre or doctor for treatment advice.

If on skin or clothing: Take off contaminated clothing. Rinse skin immediately with plenty of water for 15-20 minutes. Call a poison control centre or doctor for treatment advice.

If inhaled: Move person to fresh air. If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably by mouth-to-mouth, if possible. Call a poison control centre or doctor for further treatment advice.

If swallowed: Call a poison control centre or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told to do so by a poison control centre or doctor. Do not give anything by mouth to an unconscious person.

Take container, label or product name and Pest Control Product Registration number with you when seeking medical attention.

TOXICOLOGICAL INFORMATION:

Probable mucosal damage may contraindicate the use of gastric lavage. Treat symptomatically.

NOTICE TO USER:

This pest control product is to be used only in accordance with the directions on the label. It is an offence under the Pest Control Products Act to use this product in a way that is inconsistent with the directions on the label.

ENVIRONMENTAL HAZARDS:

This product is toxic to fish. Do not discharge into lakes, streams, ponds or public waters.

PHYSICAL AND CHEMICAL HAZARDS:

Strong oxidizing agent. Mix only with water. Use clean dry utensils. Do not add this product to any dispensing device containing remnants of any other product. Such use may cause a violent reaction leading to fire and explosion. Contamination with moisture, organic matter or other chemicals may start a chemical reaction with fire and explosion. In case of contamination or decomposition do not reseal container. If possible, isolate container in open air or well ventilated area, if necessary flood with large volumes of water.

2021-6463

2022-01-14

STORAGE AND DISPOSAL:

1. Triple- or pressure-rinse the empty container. Add the rinsings to the spray mixture in the tank.
2. Follow provincial instructions for any required additional cleaning of the container prior to disposal.
3. Make the empty container unsuitable for further use.
4. Dispose of the container in accordance with provincial requirements.
5. For information on disposal of unused, unwanted product, contact the manufacturer or the provincial regulatory agency. Contact the manufacturer and the provincial regulatory agency in case of a spill, and for clean-up of spills.