

2012-5198
2013-07-26

ZEP TOWER 610™

LIQUID MICROBICIDE

INDUSTRIAL

READ THE LABEL BEFORE USING

**BROAD SPECTRUM LIQUID MICROBICIDE FOR THE CONTROL OF ALGAE, BACTERIA AND FUNGI
NON FOAMING – EFFECTIVE AT BOTH ACID AND ALKALINE pH
NOT INTENDED FOR USE IN POTABLE WATER SYSTEMS.
FOR FOOD PLANT & OTHER INDUSTRIAL USE ONLY.**

REGISTRATION NO.: 26283 – PEST CONTROL PRODUCTS ACT

GUARANTEE: Poly[oxyethylene(dimethyliminio)ethylene
(dimethyliminio)-ethylene dichloride] 10% (by weight)

ENVIRONMENTAL HAZARDS: This product is toxic to aquatic organisms. Keep out of lakes, streams or ponds. Do not contaminate water, food, or feed by storage or disposal.

NOTICE TO USER: This pest control product is to be used only in accordance with the direction on the label. It is an offense under the Pest control Products Act to use this product in a way that is inconsistent with the directions on the label. The user assumes the risk to persons or property that arises from any such use of this product.

DIRECTIONS FOR USE

DO NOT discharge effluent containing this product into sewer systems, lakes, streams, ponds, estuaries, oceans, and other waters.

DO NOT contaminate irrigation or drinking water supplies or aquatic habitats by cleaning of equipment or disposal of wastes.

1) Cooling Tower Systems: Prior to use in water cooling towers, systems should be cleaned to remove organic, inorganic and microbiological deposits. An initial slug addition of 420 to 1050 mL per 10,000 liters of water should then be added to the sump of the cooling water towers. Repeat the initial dosage until control is evident. Subsequent slug additions of 120 to 1050 mL per 10,000 liters of water should be added every 2 to 5 days or as needed. The frequency of addition will depend on the relative amount of bleedoff and the severity of the microbiological problem.

2) Industrial Air Washing Systems: Prior to use in air washers, systems should be cleaned to remove organic, inorganic and microbiological deposits. An initial slug addition of 150 to 240 mL per 1,000 liters of water should then be added to the sump or the water collector trays. Repeat the initial dosage until control is evident. Subsequent slug additions of 105 to 240 mL per 1,000 liters of water should be added every 1 to 5 days or as needed. The frequency of addition will depend on the relative amount of bleedoff and the severity of the microbiological problem. For use only in systems equipped with effective mist eliminating components.

PRECAUTIONS – KEEP OUT OF REACH OF CHILDREN

Do not mix with any other chemical. Harmful if swallowed. Avoid contact with skin and eyes. Wear a long-sleeved shirt and long pants, chemical-resistant gloves and safety glasses (goggles) during handling, clean-up and repair activities. In addition, a chemical-resistant apron is required for workers handling end-use products in industrial settings. Wash thoroughly after handling. Immediately remove contaminated clothing and wash before reuse.

FIRST AID

2012-5198
2013-07-26

If in eyes: Hold eye open and rinse slowly and gently with water for 15-20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye. Call a poison control centre or doctor for treatment advice.

If on skin or clothing: Take off contaminated clothing. Rinse skin immediately with plenty of water for 15-20 minutes. Call a poison control centre or doctor for treatment advice.

If inhaled: Move person to fresh air. If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably by mouth-to-mouth, if possible. Call a poison control centre or doctor for further treatment advice.

If swallowed: Call a poison control centre or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told to do so by a poison control centre or doctor. Do not give anything by mouth to an unconscious person.

Take container, label or product name and Pest Control Product Registration Number with you when seeking medical attention.

TOXICOLOGICAL INFORMATION: Note to physician: Probable mucosal damage following ingestion may contraindicate gastric lavage. Treat symptomatically.

DISPOSAL

1. Triple or pressure rinse the empty container. Add the rinsings to the treatment site.
2. Follow provincial instructions for any required additional cleaning of the container prior to its disposal.
3. Make the empty container unsuitable for further use.
4. Dispose of the container in accordance with provincial requirements.
5. For information on the disposal of unused, unwanted product contact the Provincial Regulatory Agency or the Manufacturer. Contact the Provincial Regulatory Agency or the Manufacturer in case of a spill, and for clean-up of spills.

**Zep Manufacturing Company of Canada
11627-178 Street, Edmonton, AB T5S 1N6**

NET CONTENTS 20 LITRES

PRODUCT #245

1-877-428-9937