

2013-1732  
2014-01-16

# Kemtreet 034

LIQUID MICROBICIDE  
INDUSTRIAL

**Controls the growth of algae,  
bacteria and fungi**

**READ THE LABEL BEFORE USING**

**REGISTRATION NO. : 26226  
PEST CONTROL PRODUCTS ACT**

**GUARANTEE:**

Potassium dimethyldithiocarbamate ..... 10% (by wt)

**WARNING**

**POISON CORROSIVE**

**CORROSIVE TO EYES**

**SKIN IRRITANT**

**POTENTIAL SKIN SENSITIZER**

NET CONTENTS: liters

**KEM Canada Mfg.**

**1875 Drew Road, Mississauga, Ontario**

**L5S 1J5**

**ENVIRONMENTAL HAZARDS:** This product is toxic to fish and other aquatic organisms. Keep out of lakes, streams or ponds. Do not contaminate water, food, or feed by storage or disposal.

**NOTICE TO USER:** This pest control product is to be used only in accordance with the directions on the label. It is an offence under the Pest Control Products Act to use this product in a way that is inconsistent with the directions on the label. The user assumes the risk to persons or property that arises from any such use of this product.

**DIRECTIONS FOR USE**

**1) Cooling Tower Systems:**

2013-1732  
2014-01-16

Prior to use in water cooling towers, systems should be cleaned to remove organic, inorganic and microbiological deposits. An initial slug addition of 800 to 1200 mL per 10,000 liters of water should then be added to the sump of the cooling water towers. Repeat the initial dosage until control is evident. Subsequent slug additions of 400 to 1200 mL per 10,000 liters of water should be added every 2 to 5 days or as needed. The frequency of addition will depend on the relative amount of bleedoff and the severity of the microbiological problem.

## **2) Industrial Air Washing Systems:**

Prior to use in air washers, systems should be cleaned to remove organic, inorganic and microbiological deposits. An initial slug addition of 186 to 236 mL per 1,000 liters of water should then be added to the sump or the water collector trays. Repeat the initial dosage until control is evident.

Subsequent slug additions of 86 to 236 mL per 1,000 liters of water should be added every 1 to 5 days or as needed. The frequency of addition will depend on the relative amount of bleedoff and the severity of the microbiological problem. For use only in systems equipped with effective mist eliminating components.

**DO NOT discharge** effluent containing this product into sewer systems, lakes, streams, ponds, estuaries, oceans or other waters.

DO NOT contaminate irrigation or drinking water supplies or aquatic habitats by cleaning of equipment or disposal of wastes.

## **PRECAUTIONS**

### **KEEP OUT OF REACH OF CHILDREN**

Harmful if swallowed. Corrosive to the eye. DO NOT get in eyes. Corrosive to skin. DO NOT get on skin. Potential skin sensitizer. Avoid contact with clothing and avoid the contamination of food. Wear long-sleeved shirt, long pants, chemical-resistant gloves, protective eyewear (goggles or face shield) when handling the product, clean-up and repair activities.

### **FIRST AID**

**Eye exposure:** Hold eye open and rinse slowly and gently with water for 15–20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye. Call a poison control centre or doctor for treatment advice.

**Skin or clothing exposure:** Take off contaminated clothing. Rinse skin immediately with plenty of water for 15–20 minutes. Call a poison control centre or doctor for treatment advice.

**Inhalation:** Move person to fresh air. If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably by mouth-to-mouth, if possible. Call a poison control centre or doctor for further treatment advice.

**Ingestion:** Call a poison control centre or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told to do so by a poison control centre or doctor. Do not give anything by mouth to an unconscious person.

Take container, label or product name and Pest Control Product Registration Number with you when seeking medical attention.

### **TOXICOLOGICAL INFORMATION:**

Note to physician: Probable mucosal damage following ingestion may contraindicate gastric lavage. Avoid giving alcohol or alcohol related products. Treat symptomatically.

### **DISPOSAL**

1. Triple or pressure rinse the empty container. Add the rinsings to the treatment site.
2. Follow provincial instructions for any required additional cleaning of the container prior to its disposal.
3. Make the empty container unsuitable for further use.
4. Dispose of the container in accordance with provincial requirements.
5. For information on disposal of unused, unwanted product contact the manufacturer or the provincial regulatory agency. Contact the manufacturer and the provincial regulatory agency in case of a spill, and for clean-up of spills.