

2020-5177
2021-06-17

K-BAC 1020
SOLUTION

A MICROBIOCIDAL BACTERICIDE, FUNGICIDE, ALGICIDE AND SLIMICIDE, IN TREATING RECIRCULATING COOLING WATER IN INDUSTRIAL COOLING SYSTEMS AND FOR PAPER MILLS, NON-MARINE USES IN ENHANCED OIL RECOVERY SYSTEMS, METAL-WORKING CUTTING FLUIDS CONTAINING WATER OIL FIELD APPLICATIONS, FRACTURING FLUIDS, ENHANCED OIL RECOVERY (EOR) FLUIDS, AND WATER FLOOD.

ACTIVE INGREDIENT:

2,2-Dibromo-3-nitrilopropionamide 20%

COMMERCIAL

REGISTRATION NO. 31032

PEST CONTROL PRODUCTS ACT

DANGER

POISON CORROSIVE

DANGER - CORROSIVE TO EYES AND SKIN
POTENTIAL SKIN SENSITIZER
READ THE LABEL BEFORE USING
KEEP OUT OF REACH OF CHILDREN

NET CONTENTS: 5-3000 Litres

WATER SCIENCE TECHNOLOGIES, LLC
1701 Vanderbilt Road
Birmingham, AL
35234, USA
Phone: 866-284-9244

PRECAUTIONS
KEEP OUT OF REACH OF CHILDREN
HAZARD TO HUMANS AND DOMESTIC ANIMALS
DANGER CORROSIVE TO EYES AND SKIN

POTENTIAL SKIN SENSITIZER

May be harmful or fatal if swallowed or inhaled. Do not get in eyes, on skin or on clothing. Do not inhale vapours or spray mist. Wear a long-sleeve shirt, long pants, shoes plus socks, full face protection and chemical-resistant gloves when handling. Wear a respirator if the area is not well ventilated and during cleaning, maintenance and repair activities. Users should wash hands and face before eating, drinking, chewing gum, using tobacco, or using the toilet. Users should remove clothing immediately if pesticide comes in contact with skin through soaked clothing or spills. Then wash skin thoroughly and put on clean clothing. Wash contaminated clothing separate from other laundry prior to reuse. Users should remove protective clothing immediately after handling this product. Wash the outside of gloves before removing. As soon as possible, wash thoroughly and change into clean clothing.

ENVIRONMENTAL PRECAUTIONS

This product is toxic to fish and other aquatic organisms. It is not to be used in circumstances that would cause or allow it to enter lakes, streams, ponds, estuaries, oceans or other waters in contravention of federal or provincial regulatory requirements. The requirements of applicable laws should be determined before using the product.

Do not discharge effluent containing this product into sewer systems without previously notifying the local sewage treatment plant authority.

NOTE: Do not discharge treated water into estuaries, lakes, streams, ponds, or public waters.

CHEMICAL AND PHYSICAL PRECAUTIONS

Reaction with strong reducing agents may be explosive. Avoid misting.

FIRST AID:

IF SWALLOWED: Call a poison control centre or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told to do so by a poison control centre or doctor. Do not give anything by mouth to an unconscious person.

IF ON SKIN OR CLOTHING: Take off contaminated clothing. Rinse skin immediately with plenty of water for 15–20 minutes. Call a poison control centre or doctor for treatment advice.

IF INHALED: Move person to fresh air. If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably by mouth-to-mouth, if possible. Call a poison control centre or doctor for further treatment advice.

IF IN EYES: Hold eye open and rinse slowly and gently with water for 15–20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye. Call a poison control centre or doctor for treatment advice.

Take container, label or product name and Pest Control Product Registration Number with you when seeking medical attention.

TOXICOLOGICAL INFORMATION: Dilution of an ingested corrosive is a safer first aid treatment than emesis. Treat symptomatically.

STORAGE: To maintain product quality store in a dark, cool, dry, well-ventilated area, not above 30°C, rotate and use stock within three months. Store in well- closed original containers, away from energy sources, combustible organic materials and oxidizers. Do not contaminate water, food or feed by storage or disposal.

DISPOSAL:

1. Triple- or pressure-rinse the empty container. Add the rinsings to the treatment site.
2. Follow provincial instruction for any required additional cleaning of the container prior to its disposal.
3. Make the empty container unsuitable for further use.
4. Dispose of the container in accordance with provincial requirements.
5. For information on disposal of unused, unwanted product, contact the manufacturer or the provincial regulatory agency. Contact the manufacturer and the provincial regulatory agency in case of a spill, and for clean-up of spills.

For SPILLS: When handling or dealing with spills, use impact-resistant goggles with side shields, or face shield; wear body-covering clothes, including impervious chemical resistant gloves and boots; use a dust respirator if misting occurs. For small spills, recover free product. Cover wet spills with 10% sodium bicarbonate solution, water and then an inert absorbent before sweeping up and disposing as described for pesticide disposal. If drum contents are contaminated or decomposing, isolate unsealed drum in the open or in a well ventilated area; flood with 10% sodium bicarbonate solution and large volumes of water if necessary. **DO NOT FLUSH INTO SURFACE STREAMS. INFORM THE PROVINCIAL REGULATORY AUTHORITY OR THE REGISTRANT.**

NOTICE TO USER: This pest control product is to be used only in accordance with the directions on the label. It is an offense under the *Pest Control Products Act* to use this product in a way that is inconsistent with the directions on the label.

1.20 KG K-BAC 1020 LIQUID per L

DO NOT SHIP WITH FOOD, FEEDS, DRUGS OR CLOTHING

DIRECTIONS FOR USE

DIRECTIONS FOR TREATING INDUSTRIAL RECIRCULATING COOLING WATER IN INDUSTRIAL COOLING

This product is for recirculating water systems only.

NOTE: Add K-BAC 1020 separately to the system. Do not mix it with other additive, so as to avoid decomposition of K-BAC 1020 due to the high pH of many additive formulations. Add K-BAC 1020 to the basin (or any other point of uniform mixing). Addition should be made via a metering pump; it may be continuous or intermittent, depending on the severity of the contamination when treatment is begun, and the in-system retention time.

Optimum performance with this product is achieved by continuous or intermittent treatment. If "shock" treatment is used, the blowdown should be discontinued for 24-48 hours.

FOR CONTROL OF BACTERIA

Add 0.00095-0.0095L of K-BAC 1020/1000L of water in the system depending on the severity of contamination.

INTERMITTENT OR SLUG METHOD

Initial Dose: When the system is noticeably fouled, add 0.0048- 0.0095L K-BAC 1020/1000L of water in the system. Repeat until control is achieved.

Subsequent Dose: When microbial control is evident, add 0.0024-0.0095L K-BAC 1020/1000L of water in the system every 4 days, or as needed to maintain control. Badly fouled systems must be cleaned before treatment is begun.

CONTINUOUS FEED METHOD

Initial Dose: When the system is noticeably fouled, add 0.0048- 0.0095L of K-BAC 1020 /1,000 L of water to the system.

Subsequent Dose: Maintain this level by pumping a continuous feed of 0.00095-0.0048L of K-BAC 1020/1,000 L of water in the system lost by blowdown. Badly fouled systems must be cleaned before treatment is begun.

FOR CONTROL OF FUNGI AND ALGAE

Add 0.029-0.095 L of K-BAC 1020/1,000 L of water in the system depending on the severity of contamination.

INTERMITTENT OR SLUG METHOD

Initial Dose: When the system is noticeably fouled, add 0.048- 0.095L of K-BAC 1020/1000L of water in the system. Repeat until control is achieved. Subsequent

Dose: When microbial control is evident, add 0.029- 0.095L K-BAC 1020/1,000 L of water to the system daily, or as needed to maintain control. Badly fouled systems must be cleaned before treatment is begun.

CONTINUOUS FEED METHOD

Initial Dose: When the system is noticeably fouled, add 0.048- 0.095 L of K-BAC 1020/1,000 L of water in the system.

Subsequent Dose: Maintain this treatment level by pumping a continuous feed of 0.029-0.095L of K-BAC 1020/ 1,000 L of water in the system per day. Badly fouled systems must be cleaned before treatment is begun.

DIRECTIONS FOR TREATING PULP AND PAPER MILL SYSTEMS:

NOTE: Add K-BAC 1020 separately to the system. Do not mix it with other additives, so as to avoid decomposition of K-BAC 1020 due to the high pH of many additive formulations. For the control of slime forming bacterial, fungal, and yeast growth in pulp, paper and paperboard mills add K-BAC 1020 at levels of 0.075-0.210 KG/tonne (dry) or pulp or paper produced.

Addition can be continuous or intermittent, depending upon the type of system and the severity of contamination. Addition is via a metering pump at a point in the system that will ensure uniform distribution of K-BAC 1020 in the mass of fiber and water, such as the beaters, Jordan inlet or discharge, broke chests, furnish chests, savealls and white-water tanks. Heavily fouled systems must first be boiled out, then treated with 0.075- 0.175 KG of K-BAC 1020 (PEG)/tonne (dry) of paper or pulp as necessary for control. Moderately fouled systems should be treated continuously with 0.175-0.210 KG of K-BAC 1020/tonne (dry) of paper or pulp until the slime accumulation is controlled. Subsequent rates can then be reduced to 0.075-0.175 KG of K-BAC 1020 tonne (dry) of paper on continuous or intermittent basis as needed for control. Dislodged slime may cause breaks in the paper and a cleanup of the paper machine may be advisable. Slightly fouled systems should be treated continuously with 0.075-0.175 KG of K-BAC 1020/tonne (dry) of paper or pulp, until the slime is controlled, then added on an intermittent basis to maintain control.

DIRECTIONS FOR TREATING ENHANCED OIL RECOVERY SYSTEMS (NON-MARINE USES)

NOTE: Add K-BAC 1020 separately to the system. Do not mix with other additives, so as to avoid decomposition of K-BAC 1020 due to the high pH of many additive formulations. Addition of K-BAC 1020 may be made at the free-water knockouts, before or after the injection pumps and injection well headers.

For controlling slime-forming bacteria, sulfide-producing bacteria, yeasts, and fungi in oil field water, polymer or micellar floods, water-disposal systems, or other oil field water systems, add 1-80 ppm K-BAC 1020 (0.38-24.23 L of K-BAC 1020 per 2400 barrels of water) depending on the severity of contamination.

Additions should be made with a metering pump either continuously or intermittently.

CONTINUOUS FEED METHOD:

When the system is noticeably fouled, add 10-80 ppm K-BAC 1020 (3.03-24.23 L of K-BAC 1020 per 2400 barrels of water) continuously until the desired degree of control is achieved. Subsequently, treat with 1-15 ppm K-BAC 1020 (0.38-4.54 of K-BAC

1020 per 2400 barrels of water) continuously or as needed to maintain control.

INTERMITTENT OR SLUG METHOD:

When the system is noticeably fouled or to maintain control of the system, add 10-80 ppm K-BAC 1020 (3.03-24.23 L of K-BAC 1020 per 2400 barrels of water) intermittently for 4-8 hours per day and from 1-4 times per week, or as needed depending on the severity of contamination. NOTE: For control of bacteria, yeast, and fungi in aqueous solutions of biopolymer used in flooding operations, add 15-80 ppm K-BAC 1020 (4.54-24.23 L of K-BAC 1020 per 2400 barrels of water). Additions of K-BAC 1020 should be made with a metering pump immediately after preparation of the aqueous biopolymer solution to prevent loss of viscosity.

DIRECTIONS FOR TREATING METAL - WORKING CUTTING FLUIDS CONTAINING WATER

K-BAC 1020 is effective in metal working fluid concentrates which have been diluted in water at ratios of 1:100 to 1:4. For controlling (or inhibiting) the growth of bacteria, fungi and yeasts that may deteriorate metal working fluids containing water, add this product to the fluid in the collection tank. Additions should be made with a metering pump.

INITIAL OR SLUG DOSE:

When the system is noticeably fouled, add K-BAC 1020 at the rate of 0.25 L (318 g) per 1000 L of metal working fluid in the system. Repeat until control is achieved. Subsequent Dose: When microbial control is evident, add K-BAC 1020 at the rate of 0.1 to 0.2 litres (127 to 254 grams) per 1000 litres of metal working fluid per day, or as needed to maintain control. Additions of K-BAC 1020 can be made continuously or intermittently. Slug the system as required.

OIL FIELD APPLICATIONS

For reduction of bacterial contamination and degradation in oil recovery operations, add product to the system at a rate of 0.8 mL to 64 mL per 1000 L water (1.0 to 80 ppm product) depending on the severity of contamination. Add at a point of uniform mixing, at the concentration within the stated dosing range for the relevant product application. Subsequent treatments can be applied, as needed, to maintain an effective microbial control concentration, within the described dosage range. The stated concentration ranges provide microbial control of microorganisms at differing levels of contamination.

FRACTURING FLUIDS

The product reduces bacterial contamination and degradation of fracturing fluids and gels used in oil and gas well stimulations. The product must be added to the water storage tanks before gelling and circulated to ensure mixing. The product can be added at the well head for "on-the-fly" fracturing jobs. Dose: The product must be added at a rate of 20 mL to 64 mL per 1000 L water (25 to 80 ppm product) depending on water quality. Retreat after 48 hours if the frac job is delayed.

ENHANCED OIL RECOVERY (EOR) FLUIDS

The product reduces bacterial contamination and degradation of EOR polymers and

gels. The product must be added to injection water before polymer addition. Dose: The product must be added at a rate of 0.8 mL to 64 mL per 1000 L water (1.0 to 80 ppm product). Product must be added at a point to ensure proper mixing.

WATER FLOOD

The product can be used to control slime and corrosion causing bacteria in waters used for secondary oil and gas recovery. If the system is heavily fouled, slug treat at the higher rate to remove biofilm. For maintenance, batch treat two to three times per week. Dose: The product must be added at a rate of 0.8 mL to 64 mL per 1000 L water (1.0 to 80 ppm product). Product must be added at a point to ensure uniform mixing.