

**BROAD SPECTRUM LIQUID MICROBICIDE
FOR THE CONTROL OF ALGAE, BACTERIA AND
FUNGI
NON FOAMING**

DIRECTIONS FOR USE

1) Cooling Tower Systems:

Prior to use in water cooling towers, systems should be cleaned to remove organic, inorganic and microbiological deposits. An initial slug addition of 500 to 1000 mL per 10,000 litres of water should then be added to the sump of the cooling water towers. Repeat the initial dosage until control is evident. Subsequent slug additions of 200 to 1000 mL per 10,000 litres of water should be added every 2 to 5 days or as needed. The frequency of addition will depend on the relative amount of bleedoff and the severity of the microbiological problem.

Date Created:- 08/16/2002

C.B.T. BIO C

**LIQUID MICROBICIDE
INDUSTRIAL**

READ THE LABEL BEFORE USING

**REGISTRATION NO: 27300 PEST
CONTROL PRODUCTS ACT.**

GUARANTEE:

Potassium N-methyldithiocarbamate ... 5.07% (by wt)
Disodium cyanodithioimidocarbonate ...3.68% (by wt)



POISON

WARNING



CORROSIVE

NET CONTENTS: Kg.

ENVIRONMENTAL HAZARDS

This product is toxic to fish. Keep out of lakes, streams or ponds.
Do not contaminate water, food or feed by storage or disposal.
Do not reuse empty container.

NOTICE TO USER

This control product is to be used only in accordance with the directions on this label. It is an offense under the Pest Control Products Act to use a control product under unsafe conditions.

NOTICE TO BUYER

Seller's guarantee shall be limited to the terms set out on the label and subject thereto, the buyer assumes the risk to persons or property arising from the use or handling of this product and accepts the product on that condition.

PRECAUTIONS

DANGER KEEP OUT OF REACH OF CHILDREN

Harmful if swallowed. Avoid contact with eyes, skin, clothing and the contamination of food. Wear safety glasses (goggles), rubber gloves and body-protective clothing.

FIRST AID

Take container, label or product name and Pest Control Product Registration Number with you when seeking medical attention.

Eye exposure: Immediately flush with plenty of water for at least 15 to 30 minutes or longer until irritation subsides. Do not remove contact lenses if worn. Get immediate medical attention.

Skin Exposure: Immediately wash with plenty of soap and water. Get medical attention.

Inhalation: Remove to fresh air. If breathing is difficult, administer oxygen. If symptoms persist, call a physician.

Ingestion: DO NOT INDUCE VOMITING. Rinse mouth with copious amounts of water or milk first. Irrigate the esophagus and dilute stomach contents by slowly giving one (1) to two (2) glasses of water or milk. Avoid giving alcohol or alcohol related products. In cases where the individual is semi-comatose, comatose or convulsing, DO NOT GIVE FLUIDS BY MOUTH. In all cases, seek IMMEDIATE medical assistance or contact the poison control centre.

TOXICOLOGICAL INFORMATION

Note to Physician: Probable mucosal damage following ingestion may contraindicate the use of gastric lavage.

DISPOSAL

Do not reuse this container for any purpose. This is a recyclable container, and is to be disposed of at a container collection site. Contact your local distributor/dealer or municipality for the location of the nearest collection site. Before taking the container to the collection site:

1./ Triple or pressure-rinse the empty container. Add the rinsings to the treatment site.

2./ Make the empty, rinsed container unusable for further use.

If there is no container collection site in your area, dispose of the container in accordance with provincial requirements.

For information on disposal of unused, unwanted product, contact the manufacturer or the Provincial Regulatory Agency.

Contact the manufacturer and the Provincial Regulatory Agency in case of spill, and for clean-up of spills.



CUSTOM BLENDED TREATMENTS LIMITED

54 Guelph Avenue, Unit 5 Cambridge, Ontario N3C 2V8

Telephone Office (519) 822-0954, Plant (519) 658-1130 / Fax (519) 658-2500

BATCH NUMBER: _____

This label transcript service is offered by the Pest Management Regulatory Agency to provide efficient searching for label information. This service and this information do not replace the official hard-copy label. The PMRA does not provide any guarantee or assurance that the information obtained through this service is accurate, current or correct, and is therefore not liable for any loss resulting, directly or indirectly, from reliance upon this service.