ANCO

SUPERIOR WATER-TREATING SERVICE

ANCOCIDE 4070

INDUSTRIAL MICROBICIDE FOR USE IN RECIRCULATING WATER COOLING TOWERS AND AIR WASHER SYSTEMS

COMMERCIAL

GUARANTEE:

5-Chloro-2-methyl-4-isothiazolin-3-one	. 1	.13%
2-methyl-4-isothiazolin-3-one	. 0	.37%

REGISTRATION NO. 22430 PEST CONTROL PRODUCTS ACT

> WARNING CORROSIVE

READ THE LABEL BEFORE USING DO NOT USE IN POTABLE WATER SYSTEMS

NET CONTENTS ON DRUM

MANUFACTURED FOR:
ANDERSON CHEMICAL COMPANY, LTD.
P.O. Box 33029 - 1229 Oxford Street
London, Ontario Canada
N5Y 5L4

PRECAUTIONS DANGER:

CORROSIVE TO EYES AND CAUSES SKIN BURNS.

MAY CAUSE ALLERGIC SKIN REACTION

MAY BE FATAL IF SWALLOWED OR ABSORBED THROUGH THE SKIN.

Do not get in eyes, on skin, on clothing. Wear goggles or face shield and rubber gloves when handling. Avoid breathing vapor or mist. Do not take internally. Wash thoroughly after handling. This product is toxic to fish and wildlife. Treated effluent should not be discharged where it will drain into lakes, streams, ponds or public water. Do not contaminate water by cleaning of equipment or disposal of waters. Apply this product only as specified on this label.

STORAGE

Do not contaminate water, food, or feed by storage or disposal. Open dumping is prohibited. If plastic, do not reuse empty container.

DISPOSAL

- 1. Rinse the emptied container thoroughly and add the rinsings to treatment site.
- 2. Follow provincial instruction for any required additional cleaning of the container prior to its disposal or reconditioning.
- 3. Dispose of the container in accordance with provincial requirements.
- 4. For information on the disposal of unused, unwanted product and the cleanup of spills contact the regional office of CONSERVATION and PROTECTION SERVICE, ENVIRONMENT CANADA.
- 5. For small spills. Recover free liquid. Soak up residue with solids absorbent. Do not flush into surface streams. INFORM ENVIRONMENT CANADA AS IN #4.

NOTICE TO USER:

This control product is to be used only in accordance with the directions on this label. It is an offence under the Pest Control Products Act to use a control product under unsafe conditions.

NOTICE TO BUYER:

Seller's guarantee shall be limited to the terms of the label and subject thereto, the buyer assumes the risk to persons or property arising from the use or handling of this product and accepts the products on these conditions.

DIRECTIONS FOR USE:

COOLING TOWERS ANCOCIDE 4070 is recommended for the removal of slime from fouled towers, add 0.33 to 8.67 kg of ANCOCIDE 4070 as supplied per 10 tonnes of water in the system (equivalent to about 0.5 to 13 ppm active ingredient). This dosage should be repeated 12 to 3 times per week until fouling has been reduced to an acceptable level thus establishing microbial control.

POINT OF ADDITION:

ANCOCIDE 4070 should be added to the basin to the distribution boxes, or at any other point where it will be rapidly and uniformly dispersed throughout the system.

FIRST AID:

Do not induce vomiting. Drink promptly a large quantity of milk, egg whites, gelatin solution or if these are not available, drink large quantities of water. Avoid alcohol. Call a physician

immediately.

IF INHALED:

Remove immediately to fresh air. If not breathing, apply artificial respiration. If breathing is difficult, give oxygen. Call a physician.

IN ON SKIN:

Wash thoroughly with soap and water remove, wash contaminated clothing before reuse.

IF IN EYES:

Flush with plenty of water for at least 15 minutes. Call a physician.

TOXICOLOGICAL INFORMATION:

Probable mucosal damage may contraindicate use of gastric lavage. Measures against circulatory shock, respiratory depression and convulsions, may be needed.

This label transcript service is offered by the Pest Management Regulatory Agency to provide efficient searching for label information. This service and this information do not replace the official hard-copy label. The PMRA does not provide any guarantee or assurance that the information obtained through this service is accurate, current or correct, and is therefore not liable for any loss resulting, directly or indirectly, from reliance upon this service.

+))