

95.02.07

CHIMTOX 520

Controls bacteria, fungi and yeasts in paper mills, metalworking fluids containing water, and enhanced oil recovery systems: controls bacteria and algae in industrial recirculating water cooling towers.

INDUSTRIAL

READ THE LABEL BEFORE USING

GUARANTEE:

2,2-DIBROMO-3-NITRILOPROPIONAMIDE.....20%

REGISTRATION NUMBER 23879  
PEST CONTROL PRODUCTS ACT

DANGER

POISON          CORROSIVE

CAUSES SEVERE BURNS OF EYES  
MAY BURN THE SKIN  
MAY BE HARMFUL OR FATAL  
IF SWALLOWED

- Do not get in eyes, on skin, or on clothing
- Wear Chemical Workers' goggles when handling
- Wash thoroughly after handling

Do not ship or store with food, feeds or clothing.

NET CONTENT:

PA-7 Lab 7300 St-Jacques  
Montréal, Qué., Canada  
H4B 1W1  
Tel: (514) 483-6500  
Telex: 055-66319, Local: 566  
Fax: (514) 483-3284

CHIMTOX 520

CONTAINS 2,2 DIBROMO-3-NITRILOPROPIONAMIDE

## DIRECTIONS FOR USE

NOTE: ADD CHIMTOX 520 SEPARATELY TO THE SYSTEM. DO NOT MIX IT WITH OTHER ADDITIVES IN ORDER TO AVOID DECOMPOSITION OF CHIMTOX 520 DUE TO THE HIGH PH OF MANY ADDITIVE FORMULATIONS.

PAPER MILLS: For the control of bacterial, fungal and yeast growth in pulp, paper and paperboard mills, add CHIMTOX 520 at the rate of 60-210 mL/tonne of pulp or paper (dry basis). Addition may be continuous or intermittent, depending upon the type of system and the severity of contamination. It should be made with a metering pump at a location that will insure uniform distribution of CHIMTOX 520 in the mass of fiber and water such as the beaters, Jordan inlet or discharge, broke chests, furnish chests, save-alls and white-water tanks.

## INDUSTRIAL RECIRCULATING WATER COOLING TOWERS

Add CHIMTOX 520 to the basin (or any other point of uniform mixing). Addition should be made with a metering pump. It may be continuous or intermittent, depending on the severity of the contamination when treatment is begun, and the retention time in the system.

Optimum performance with this product is attained by continuous or intermittent treatment. If "shock" treatment is used, the blowdown should be discontinued for 24-48 hours.

## DISPOSAL:

1. Rinse the emptied container thoroughly and add the rinsings to treatment site.
2. Follow provincial instructions for any required additional cleaning of the container prior to its disposal or reconditioning.
3. Dispose of the container in accordance with provincial requirements.
4. For information on the disposal of unused, unwanted product and the cleanup of spills, contact the regional office of Environment Canada.
5. For small spills. Recover free liquid. Soak up residue with solids absorbent. DO NOT FLUSH INTO SURFACE STREAMS. INFORM ENVIRONMENT CANADA AS IN #4.

## FIRST AID

In case of eye contact, flush eyes immediately with plenty of water for at least 15 minutes and get medical attention. In case of skin contact, wash with soap and plenty of water. Wash

contaminated clothing before re-use.

If swallowed, induce vomiting by sticking finger down the throat or by giving soapy or strong salty water to drink. Repeat until vomit is clear. Call a physician. Never give anything by mouth to an unconscious person.

\*\*\*\*\*

This label transcript service is offered by the Pest Management Regulatory Agency to provide efficient searching for label information. This service and this information do not replace the official hard-copy label. The PMRA does not provide any guarantee or assurance that the information obtained through this service is accurate, current or correct, and is therefore not liable for any loss resulting, directly or indirectly, from reliance upon this service.

+))