

2023-1795
2023-06-26

SPECTRUS NX1105
MICROBISTAT
INDUSTRIAL

DANGER CORROSIVE

CORROSIVE TO EYES AND SKIN

READ THE LABEL BEFORE USING

ACTIVE INGREDIENTS:

Glutaraldehyde.....45.0%

REGISTRATION NO. 21044
PEST CONTROL PRODUCTS ACT
NET CONTENTS: (20 TO 1,000 L)

Veolia Water Technologies & Solutions Canada GP
3239 Dundas Street West
Oakville, ON L6M 4B2

EMERGENCY TELEPHONE NUMBERS
TRANSPORTATION EMERGENCIES ONLY
Canada/Canutec: 1-613-996-6666

ALL OTHER EMERGENCIES
Veolia Water Technologies & Solutions Canada GP 1-215-942-3621

NOTICE TO USER: This pest control product is to be used only in accordance with the directions on the label. It is an offense under the Pest Control Products Act to use this product in a way that is inconsistent with the directions on the label. The user assumes the risk to persons or property that arises from any such use of this product.

FOR INDUSTRIAL USE ONLY: Technical advice regarding specific site problems is available from Veolia Water Technologies & Solutions Canada GP.

PRECAUTIONS:

KEEP OUT OF REACH OF CHILDREN.

DANGER. CORROSIVE TO EYES AND CAUSES SKIN BURNS. MAY CAUSE ALLERGIC SKIN REACTION. MAY BE HARMFUL IF INHALED. MAY BE FATAL IF SWALLOWED. Do not get in eyes, on skin, on clothing. Wear goggles or face shield and rubber gloves when handling. Avoid breathing vapor or mist. Do not take internally. Wash thoroughly after handling. DO NOT USE IN POTABLE WATER. Do not contaminate water, food or feed by storage or disposal.

FIRST AID:

If swallowed. Call a poison control center or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told to do so by a poison control center or doctor. Do not give anything by mouth to an unconscious person.

If on skin or clothing. Take off contaminated clothing. Rinse skin immediately with plenty of water for 15–20 minutes. Call a poison control center or doctor for treatment advice.

If inhaled Move person to fresh air. If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably by mouth-to-mouth, if possible. Call a poison control center or doctor for further treatment advice.

If in eyes Hold eye open and rinse slowly and gently with water for 15–20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye. Call a poison control center or doctor for treatment advice.

2023-1795
2023-06-26

Take container, label or product name and Pest Control Product Registration Number with you when seeking medical attention.

TOXICOLOGICAL INFORMATION:

Probable mucosal damage may contraindicate the use of gastric lavage. Measures against shock, respiratory depression and convulsion may be needed.

ENVIRONMENTAL HAZARDS: Open dumping is prohibited. If plastic, do not reuse empty container. This product is toxic to fish and wildlife. Treated effluent should not be discharged where it will drain into lakes, streams, ponds or public water. Do not contaminate water by cleaning of equipment or disposal of wastes. Apply this product only as specified on this label.

STORAGE: KEEP FROM FREEZING.

DISPOSAL:

1. Triple- or pressure-rinse the empty container. Add the rinsings to the treatment area or, if applicable, to the spray mixture in the tank.
2. Follow provincial instruction for any required additional cleaning of the container prior to its disposal.
3. Make the empty container unsuitable for further use.
4. Dispose of the container in accordance with provincial requirements.
5. For information on disposal of unused, unwanted product, contact the manufacturer or the provincial regulatory agency. Contact the manufacturer and the provincial regulatory agency in case of a spill, and for clean-up of spills.

DIRECTIONS FOR USE

AIR WASHERS AND RECIRCULATING COOLING WATER SYSTEMS

For use in systems with mist eliminating components only. This product may be either continuously dosed or slug dosed to an area of good agitation.

SLUG METHOD: Apply 120-240 mL of this product per 1000L of system volume. Repeat until control is achieved. When control is evident, reduce dosage to 50-120 mL per 1000 L of system volume added weekly or as needed to maintain control.

CONTINUOUS FEED METHOD: Initially add 120-240 mL of this product per 1000L of system volume, maintain treatment level by continuously feeding 25-120 mL of this product per 1000L of system volume per day.