

2015-5000
2016-03-01

BW 110
LIQUID MICROBIOCIDE
INDUSTRIAL

READ THE LABEL BEFORE USING

REGISTRATION NO.: 22277
PEST CONTROL PRODUCTS ACT

GUARANTEE

Poly[oxyethylene(dimethyliminio)ethylene((dimethyliminio)-ethylene dichloride)]...10%

NET CONTENTS: litres

ENVIRONMENTAL HAZARDS:

This product is toxic to fish and other aquatic organisms. Keep out of lakes, streams or ponds. Do not contaminate water, food or feed by storage or disposal.

NOTICE TO USER:

This pest control product is to be used only in accordance with the directions on the label. It is an offence under the Pest Control Products Act to use this product in a way that is inconsistent with the directions on the label. The user assumes the risk to persons or property that arises from any such use of this product.

KIMIK'O Inc.

1375-B Ernest-Harnois
Joliette, Québec J6E 0L7
Tel : 450-867-1825

**BROAD SPECTRUM LIQUID
MICROBIOCIDE
FOR THE CONTROL OF ALGAE
BACTERIA AND FUNGI**

**NON FOAMING
EFFECTIVE AT BOTH ACID AND
ALKALINE Ph**

DIRECTIONS FOR USE

DO NOT discharge effluent containing this product into sewer systems, lakes, streams, ponds, estuaries, oceans, and other waters.

DO NOT contaminate irrigation or drinking water supplies or aquatic habitats by cleaning of equipment or disposal of wastes.

1) Cooling Tower Systems:

Prior to use in water cooling towers, systems should be cleaned in order to remove organic, inorganic, microbiological deposits.. An initial slug addition of 420ml to 1,050 ml per 10,000 litres of water should then be added to the sump of the cooling water towers. Repeat the initial dosage until control is evident. Subsequent slug additions of 120 ml to 1,050 ml per 10,000 litres of water should be added every 2 to 5 days or as needed. The frequency of addition will depend on the relative amount of bleed off and the severity of the microbiological problem.

2) Industrial Air Washing Systems:

Prior to use in air washers, systems should be cleaned to remove organic, inorganic and microbiological deposits. An initial slug addition of 150 ml to 240 ml per 1,000liters of water should then be added to the sump or the water collector trays. Repeat the initial dosage until the control is evident.

Subsequent slug additions of 110 ml to 240 ml per 1,000liters of water should be added every 1 to 5 days or as needed. The frequency of addition will depend on the relative amount of bleed off and the severity of the microbiological problem.

For use only in systems equipped with the effective mist eliminating components.

Modifications: 15/09/05

PRECAUTIONS

KEEP OUT OF REACH OF CHILDREN

Do not mix with any other chemical. Harmful if swallowed. Avoid contact with skin and eyes. Wear a long-sleeved shirt, long pants, chemical-resistant gloves and safety glasses (goggles) during handling, clean-up and repair activities. In addition, a chemical-resistant apron is required for workers handling end-use products in industrial settings. Wash thoroughly after handling. Immediately remove contaminated clothing and wash before reuse.

FIRST AID

If in eyes: hold eye open and rinse slowly and gently with water for 15-20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye. Call a poison control centre or doctor for treatment advice.

If on skin or clothing: take off contaminated clothing. Rinse skin immediately with plenty of water for 15-20 minutes. Call a poison control centre or doctor for treatment advice.

If inhaled: move person to fresh air. If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably by mouth-to-mouth, if possible. Call a poison control centre or doctor for further treatment advice.

If swallowed: call a poison control centre or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told to do so by a poison control centre or doctor. Do not give anything by mouth to an unconscious person.

Take container, label or product name and Pest Control Product Registration Number with you when you seek medical attention.

TOXICOLOGICAL INFORMATION:

Note to physician. Probable mucosal damage following ingestion may contraindicate gastric lavage. Treat symptomatically.

DISPOSAL

1. Triple or pressure-rinse the empty container. Add the rinsings, to the treatment site.
2. Follow the provincial instructions for any additional required cleaning of the container prior to its disposal.
3. Make the container unsuitable for further use.
4. Dispose of the container in accordance with the provincial requirements.
5. For information on the disposal of unused, unwanted product, contact the Provincial Regulatory Agency or the manufacturer. Contact the manufacturer and the Provincial Regulatory Agency in case of a spill and for clean-up of spills