

2021-0433, 2021-03-01

Wetcide 4120

LIQUID MICROBICIDE
INDUSTRIAL
READ THE LABEL BEFORE USING

GUARANTEE:

Poly [oxyethylene (dimethyliminio) ethylene (dimethyliminio)-ethylene dichloride]
..... 20% (by weight)

REGISTRATION NO.: 22456
PEST CONTROL PRODUCT ACT

NET CONTENTS: 20 liters

ENVIRONMENTAL HAZARDS: This product is toxic to fish. Keep out of lakes, streams or ponds.

NOTICE TO USER: This pest control product is to be used only in accordance with the directions on the label. It is an offense under the Pest Control Products Act to use this product in a way that is inconsistent with the directions on the label. The user assumes the risk to persons or property that arises from any such use of this product.

Water Energy Technologies
3375 North Service Rd., #A7
Burlington, Ontario L7N 3G2
Tel: 905-336-7666

**BROAD SPECTRUM LIQUID MICROBICIDE
FOR THE CONTROL OF ALGAE, BACTERIA
AND FUNGI**

- NON FOAMING
- EFFECTIVE AT BOTH ACID AND ALKALINE pH

DIRECTIONS FOR USE

1) Cooling Tower Systems:

Prior to use in water cooling towers, systems should be cleaned to remove organic, inorganic and microbiological deposits. An initial slug addition of 210 to 525 mL per 10,000 liters of water should then be added to the sump of the cooling water towers. Repeat the initial dosage until control is evident. Subsequent slug additions of 60 to 525 mL per 10,000 liters of water should be added every 2 to 5 days or as needed. The frequency of addition will depend on the relative amount of bleedoff and the severity of the microbiological problem.

2) Industrial Air Washing Systems:

Prior to use in air washers, systems should be cleaned to remove organic, inorganic and microbiological deposits. An initial slug addition of 75 to 120 mL per 1,000 liters of water should then be added to the sump or the water collector trays. Repeat the initial dosage until control is evident. Subsequent slug additions of 55 to 120 mL per 1,000 liters of water should be added every 1 to 5 days or as needed. The frequency of addition will depend on the relative amount of bleedoff and the severity of the microbiological problem. For use only in systems equipped with effective mist eliminating components.

LOT 4120-21000

PRECAUTION
DANGER
KEEP OUT OF REACH OF CHILDREN

Harmful if swallowed. Avoid contact with eyes, skin, clothing and the contamination of food. Wear safety glasses (goggles), rubber gloves and body-protective clothing.

FIRST AID

If in eyes: Hold eye open and rinse slowly and gently with water for 15-20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye. Call a poison control centre or doctor for treatment advice. If on skin or clothing: Take off contaminated clothing. Rinse skin immediately with plenty of water for 15-20 minutes. Call a poison control centre or doctor for treatment advice. If inhaled: Move person to fresh air. If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably by mouth-to-mouth, if possible. Call a poison control centre or doctor for further treatment advice. If swallowed: Call a poison control centre or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told to do so by a poison control centre or doctor. Do not give anything by mouth to an unconscious person. Take container, label, or product name and Pest Control Product Registration Number with you when seeking medical attention.

TOXICOLOGICAL INFORMATION: Note to physician: Probable mucosal damage following ingestion may contraindicate gastric lavage. Treat symptomatically.

DISPOSAL

1. Triple- or pressure-rinse the empty container. Add the rinsings to the treatment site.
2. Follow provincial instructions for any required additional cleaning of the container prior to its disposal.
3. Make the empty container unsuitable for further use.
4. Dispose of the container in accordance with provincial requirements.
5. For information on the disposal of unused, unwanted product, contact the manufacturer or the provincial regulatory agency. Contact the manufacturer and the provincial regulatory agency in case of a spill, and for clean-up of spills.