

96/2001

1741  
INDUSTRIAL RECIRCULATING WATER COOLING  
TOWER MICROBIOCIDE

COMMERCIAL

GUARANTEE:

5-Chloro-2-methyl-4-isothiazolin-3-one.....1.13%  
2-Methyl-4-isothiazolin-3-one.....0.37%

REGISTRATION NO. 22146  
PEST CONTROL PRODUCTS ACT

WARNING

CORROSIVE

READ THE LABEL BEFORE USING

DO NOT USE IN POTABLE WATER SYSTEM

NET CONTENTS: \_\_\_\_\_ Kg  
                                  \_\_\_\_\_ Litres

FINNAN ENGINEERED PRODUCTS LIMITED  
1149 BELLAMY ROAD NORTH, UNIT 22  
SCARBOROUGH, ONTARIO  
M1H 1H7

PHONE (416) 438-6070 FAX (416) 438-8739

PRECAUTIONS

DANGER-CORROSIVE TO EYES AND CAUSES SKIN BURNS.

MAY CAUSE ALLERGIC SKIN REACTION.

MAY BE FATAL IF SWALLOWED OR ABSORBED THROUGH THE SKIN.

Do not get in eyes, on skin, on clothing. Wear goggles or face shield and rubber gloves when handling. Avoid breathing vapor or mist. Do not take internally. Wash thoroughly after handling. This product is toxic to fish and wildlife. Treated effluent should not be discharged where it will drain into lakes, streams, ponds or public water. Do not contaminate water by cleaning of equipment or disposal of waters. Apply this product only as specified on this label.

STORAGE: Do not contaminate water, food, or feed by storage or disposal. Open dumping is prohibited. If plastic, do not reuse empty container.

DISPOSAL:

1. Rinse the emptied container thoroughly and add the rinsings to treatment site.
2. Follow provincial instructions for any required additional cleaning of the container prior to its disposal or reconditioning.
3. Dispose of the container in accordance with provincial requirements.
4. For information on the disposal of unused, unwanted product and the cleanup of spills, contact the regional office of Conservation and Protection, Environment Canada.
5. For small spills. Recover free liquid. Soak up residue with solids absorbent. DO NOT FLUSH INTO SURFACE STREAMS. INFORM ENVIRONMENT CANADA AS IN #4.

NOTICE TO USER: This control product is to be used only in accordance with the directions on this label. It is an offence under the Pest Control Products Act to use a control product under unsafe conditions.

NOTICE TO BUYER: Seller's guarantee shall be limited to the terms set out on the label and subject thereto. The buyer assumes the risk to persons or property arising from the use or handling of this product and accepts the products on that condition.

DIRECTIONS FOR USE

COOLING TOWERS:

1741 is recommended for the removal of slime from fouled towers, add 0.33 to 8.67 kg of 1741 as supplied per 10 tonnes of water in the system (equivalent to about 0.5 to 13 ppm active ingredient). This dosage should be repeated 2 to 3 times per week until fouling has been reduced to an acceptable level thus establishing microbial control.

POINT OF ADDITION:

1741 should be added to the distribution boxes, or at any other point where it will be rapidly and uniformly dispersed throughout the system.

FIRST AID: Do not induce vomiting. Drink promptly a large quantity of milk, egg whites, gelatin solution or if these are

not available, drink large quantities of water. Avoid alcohol. Call a physician immediately.

IF INHALED: Remove immediately to fresh air. If not breathing apply artificial respiration. If breathing is difficult, give oxygen. Call a physician.

IF ON SKIN: Wash thoroughly with soap and water. Remove and wash contaminated clothing before reuse.

IF IN EYES: Flush with plenty of water for at least 15 minutes. Call a physician.

TOXICOLOGICAL INFORMATION: Probably mucosal damage may contraindicate the use of gastric lavage. Measures against circulatory shock, respiratory depression and convulsions may be needed.

BATCH No.

\*\*\*\*\*

This label transcript service is offered by the Pest Management Regulatory Agency to provide efficient searching for label information. This service and this information do not replace the official hard-copy label. The PMRA does not provide any guarantee or assurance that the information obtained through this service is accurate, current or correct, and is therefore not liable for any loss resulting, directly or indirectly, from reliance upon this service.

+))