

95.03.31

3445

FORMULA/FORMULE

INDUSTRIAL LIQUID MICROBICIDE NON FORMING  
INDUSTRIEL LIQUIDE MICROBICIDE NON MOUSSEUX

READ THE LABEL BEFORE USING

LIRE L'ETIQUETTE AVANT L'EMPLOI

KEEP OUT OF REACH OF CHILDREN

TENIR HORS DE LA PORTEE DES ENFANTS

REGISTRATION NO./NO. D'ENREGISTREMENT 17303

PEST CONTROL PRODUCTS ACT

LOI SUR LES PRODUITS ANTIPARASITAIRES

GUARANTEE/GARANTIE:

POLY(OXYETHYLENE (DIMETHYLIMINO)  
ETHYLENE (DIMETHYLIMINO)  
ETHYLENE DICHLORIDE].....18.0%

NET

Diversey Water Technologies Ltd.  
Technologies de l'eau Diversey Ltée.  
110 Second Street  
Cobourg, Ontario  
K9A 3N5  
(416) 372-3344  
(416) 372-2561 (fax)

Technologies de l'eau Diversey ltée.  
Diversey Water Technologies Ltd.  
500 Rue Meloche  
Dorval, Quebec  
H9P 2T2  
(514) 636-4420  
(514) 636-1891 (fax)

TO PREVENT ALGAE, SLIME AND FUNGI IN RECIRCULATING COOLING WATER, AIR WASHERS AND EVAPORATIVE CONDENSERS.

Formula 3445 is effective at all pH values and will not cause foam.

**DIRECTIONS FOR USE: COOLING TOWERS:** Prior to the use of Formula 3445 in water cooling towers, systems should be cleaned to remove algae growth, microbiological slime, and other deposits. Then make an initial slug addition of 235 to 585 mL of Formula 3445 per 10,000 litres of water in the system. Repeat initial dosage until control is evident. Make subsequent slug additions of 65 to 585 mL of Formula 3445 per 10,000 litres of water every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

**INDUSTRIAL AIR-WASH SYSTEMS:** Formula 3445 is employed for the control of bacteria in industrial air-wash systems that are equipped with effective mist-eliminating components. Before treatment with the microbicide is started, the air-wash system should be cleaned to remove bacterial slime and other deposits. Then it should be refilled with fresh water and treated regularly with Formula 3445 which should be added to the sump or to the water collection trays. It is recommended that a clean air-wash system be treated initially with a slug dose of 85 - 145 mL of Formula 3445 per cubic metre of water which is equivalent to 30 to 50 ppm Formula 3445. Repeat initial dosage until control is evident. Subsequent slug additions of 55 - 145 mL of Formula 3445 per cubic metre of water to provide 20 to 50 ppm Formula 3445 should be made every 1 to 5 days, or as needed. The required frequency of addition will depend upon the relative amount of bleedoff and the severity of the bacterial problem.

**PRECAUTIONS:** Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes or clothing.

**ENVIRONMENTAL HAZARDS:** This product is toxic to fish. Keep out of lakes, streams, or ponds. Do not contaminate water, food or feed by storage or disposal. Do NOT reuse empty container.

**DISPOSAL:**

1. Rinse the emptied container thoroughly and add the rinsings to the treatment site.
2. Follow provincial instructions for any required additional cleaning of the container prior to its disposal or reconditioning.

3. Dispose of the container in accordance with provincial requirements.
4. For information on the disposal of unused, unwanted product and the cleanup of spills contact the regional office of Environment Canada.
5. For small spills, recover free liquid. Soak up residue with solids absorbent. DO NOT FLUSH INTO SURFACE STREAMS. INFORM ENVIRONMENT CANADA AS IN #4.

FIRST AID INSTRUCTIONS - IF IN EYES: Immediately flush with plenty of water for at least 15 minutes. If eye irritation persists, seek medical attention. IF ON SKIN: Wash with plenty of water. IF SWALLOWED: Drink promptly a large quantity of milk, egg whites, gelatin solution or if these are not available, drink large quantities of water. Call a physician immediately.

NOTICE TO USER:

This control product is to be used only in accordance with the directions on this label. It is an offence under the Pest Control Products Act to use a control product under unsafe conditions.

Label No. 109

\*\*\*\*\*

This label transcript service is offered by the Pest Management Regulatory Agency to provide efficient searching for label information. This service and this information do not replace the official hard-copy label. The PMRA does not provide any guarantee or assurance that the information obtained through this service is accurate, current or correct, and is therefore not liable for any loss resulting, directly or indirectly, from reliance upon this service.

+))