

09-NOV-2007 Notification of a change in Registrant address.

28-MAY-2002

06-MAR-2007 Notification of a change in Registrant address.

KLENCIDE

GA 7.5

WATER TREATMENT MICROBIOCIDE

A Microbiocide For Use In Controlling Slime Forming Bacteria, Sulfate Reducing Bacteria, And Algae In Air Washer Systems, And In Recirculating Water Cooling Towers And Systems, Including Pasteurizer Cooling Water Systems, And Industrial Closed Recirculating Process Water Systems.

GUARANTEE:

Glutaraldehyde.....7.5%

REGISTRATION NO. 27118 PEST CONTROL PRODUCTS ACT

COMMERCIAL

DANGER

CORROSIVE

READ THE LABEL BEFORE USING

~~KLENZOID CO. LTD.~~

~~265 Watline Ave
Mississauga, ON
L4Z 1P3~~

Phone (905) 712-4000
Fax (905) 712-4001

~~711 Lajoie Ave.
Dorval, PQ
H9P 1G7~~

Phone (514) 636-3060
Fax (514) 636-5432

KLENZOID CO. LTD. ☐☐
UNIT 5, 2735 MATHESON BLVD E ☐☐☐
MISSISSAUGA ON L4W 4M

500-25 Watline Ave.
Mississauga, ON L4Z 2Z1

6500 TransCanada, Suite 110 ☐
Montreal, QC ☐
H4T 1X4

Notification Change

NET CONTENTS _____

Lot No. _____ Expiry Date: _____

PRECAUTIONS: DANGER

KEEP OUT OF REACH OF CHILDREN

Corrosive. Causes irreversible eye damage. Causes skin irritation. Harmful if inhaled. Harmful if swallowed. May cause allergic skin reaction. Do not get in eyes, on skin, on clothing. Avoid breathing vapor. Do not swallow. Wear goggles, protective clothing and rubber gloves. Wash thoroughly with soap and water after handling. Remove contaminated clothing and wash before reuse.

FIRST AID INSTRUCTIONS

IF IN EYES: Immediately flush with plenty of water for at least 15 minutes. Get immediate medical attention.

IF ON SKIN: Wash with plenty of soap and water. Get medical attention.

IF INHALED: Remove to fresh air. If breathing is difficult, administer oxygen. If symptoms persists, call a physician.

IF SWALLOWED: DO NOT INDUCE VOMITING. Do not give anything to drink. Call a physician or poison control centre immediately. Take container, label or product name and Pest Control Product Registration Number with you when seeking medical attention.

TOXICOLOGICAL INFORMATION

Aspiration may cause lung damage. Probable mucosal damage may contraindicate the use of gastric lavage. Measures against circulatory shock, respiratory depression and convulsions may be needed.

DISPOSAL:

1. Triple or pressure-rinse the empty container. Add the rinsings to the treatment site.
2. Follow provincial instructions for any required additional cleaning of the container prior to its disposal.
3. Make the empty container unsuitable for further use.
4. Dispose of the container in accordance with provincial requirements.
5. For information on the disposal of unused, unwanted product, contact the manufacturer or the provincial regulatory agency. Contact the manufacturer and the provincial regulatory agency in case of a spill.

STORAGE AND HANDLING:

KLENCIDE GA 7.5 solutions are incompatible with many commonly used materials of construction such as steel, galvanized iron, aluminum, tin, and zinc. These solutions can be stored and handled in baked phenolic-lined steel, polyethylene, stainless steel, or reinforced epoxy-plastic equipment. This product freezes at about -6.5°C . Therefore, unless the storage tank is inside or underground, heating and insulation may be required. If heating is needed, exposure to high temperature should be avoided. For short storage times (up to about 1 month), temperatures of up to 38°C can be tolerated but the preferred maximum storage temperatures is about 27°C .

A stainless steel centrifugal pump is suggested for transfer service. Spiral wound stainless steel with TEFLON is suitable for gaskets and packing.

NOTICE TO USER

This control product is to be used only in accordance with the directions on this label. It is an offence under the Pest Control Products Act to use a control product under unsafe conditions.

DIRECTIONS FOR USE

AIR WASHERS AND RECIRCULATING COOLING WATER SYSTEMS

This product may be used only in industrial air washer systems which have mist-eliminating components. KLENCIDE GA 7.5 should be added at the application rates described below to a water treatment system at a convenient point of uniform mixing such as the basin area. Additions can be made intermittently (SLUG DOSE) or continuously. Badly fouled systems can be shock treated with KLENCIDE GA 7.5. Under these conditions, blowdown should be discontinued for up to 24 hours.

INTERMITTENT (SLUG DOSE) METHOD

Initial Dose: When the system is noticeably fouled apply 3.2 L - 6.4 L of KLENCIDE GA 7.5 per 5000 litres of water in the system. Repeat until control is achieved.

Subsequent Dose: When microbial control is evident, add 1.28 L - 3.2 L of KLENCIDE GA 7.5 per 5000 litres of water to the system weekly, or as needed to maintain control.

Badly fouled systems must be cleaned before treatment is begun.

CONTINUOUS FEED METHOD

Initial Dose: When the system is noticeably fouled, apply 3.2 L - 6.4 L of KLENCIDE GA 7.5 per 5000 litres of water in the system.

Subsequent Dose: Maintain this treatment level by starting a continuous feed of 640 mL - 3.2 L of KLENCIDE GA 7.5 per 5000 litres of water in the system per day.

Badly fouled systems must be cleaned before treatment is begun.

PASTEURIZER COOLING WATER SYSTEMS

AVOID CONTAMINATION OF FOOD IN THE APPLICATION OF PRODUCT.

KLENCIDE GA 7.5 should be used at the same application rates, and in the same manner as described above. It should be added to the closed recirculating system at a convenient point of uniform mixing such as a basin area, sump area, or other reservoir or collecting area from which the treated water will be circulated uniformly throughout the pasteurizer cooling system.

NOTICE TO BUYER

“Seller’s guarantee shall be limited to the terms set out on the label and, subject thereto, the buyer assumes the risk to persons or property arising from the use or handling of this product and accepts the product on that condition.”

This label transcript service is offered by the Pest Management Regulatory Agency to provide efficient searching for label information. This service and this information do not replace the official hard-copy label. The PMRA does not provide any guarantee or assurance that the information obtained through this service is accurate, current or correct, and is therefore not liable for any loss resulting, directly or indirectly, from reliance upon this service.

+))